



2014

WATER QUALITY REPORT I&D SYSTEM


The City of Savannah Water Supply and Treatment Department is pleased to report that your drinking water, supplied by the I&D System, is safe. To learn more about safety regulations and testing, see the table included in this report.

SOURCE



The I&D system is supplied with surface water from Abercorn Creek, a tributary of the Savannah River. The Travis Field/Crossroads area is served by the I&D surface water system. Three groundwater wells pumping from the Floridan Aquifer are also maintained in a ready state as a backup source.

The I&D System won Best Tasting Tap Water in Georgia in 2014 from the Georgia Association of Water Professionals!




TREATMENT



In the surface water treatment process, alum and polymer are added to the water to cause fine mud particles to clump together and settle out of the water. The clear water is then filtered, disinfected with chlorine and ammonia, and balanced for pH and corrosiveness with lime and phosphate.



TESTING



In order to ensure that tap water is safe to drink, the Environmental Protection Agency regulates the amounts of certain substances allowed in public drinking water. The City of Savannah performed over 135,000 tests and procedures, on over 160 water quality parameters in 2014 to ensure you receive safe, high quality drinking water.



DISTRIBUTION



This clean, safe, drinking water is then distributed to your home. The City of Savannah provides some of the highest quality, lowest cost drinking water in the Southeast.

IMPORTANT CONTACT INFORMATION

Water Supply and Treatment Department
(912) 964-0698
24-Hour Emergency Line
(912) 351-3434
Billing Information
(912) 651-6460
Water Conservation & Education
(912) 651-2221

Environmental Protection Agency
Safe Drinking Water Hotline
1 - 800 - 426 - 4791
www.epa.gov/ow

CITY COUNCIL MEETINGS

The City of Savannah government works under the direction of City Council and the City Manager. The City Council meets every other Thursday at 2pm at City Hall (2 E. Bay St.) These meetings are open to the public.

Water Conservation

The City of Savannah encourages residents to conserve water to help protect this precious natural resource. To learn more about water conservation programs such as free water saving toilets and water conservation kits for residents, visit www.savannahga.gov or call (912) 651-2221.

All customers must follow the outdoor watering schedule:

No watering between 10am and 4pm.
Even numbered residences water Monday, Wednesday, and Saturday. Odd numbered residences water Tuesday, Thursday, and Sunday.
To report violations call 311.

TAP WATER VS. BOTTLED WATER

All sources of drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some substances. All water sources are fed by water that passes over the land or through the ground, dissolving naturally occurring minerals and materials, or picking up substances along the way. These substances may include:

- Biological substances from human, agriculture, or wildlife sources
- Inorganic substances from stormwater runoff, industrial sources, or wastewater discharges
- Pesticides and herbicides from agriculture, stormwater runoff or residential use
- Organic chemicals from industrial or domestic processes, stormwater runoff, or septic systems
- Radioactive materials that can be naturally occurring or the result of mining or other human activities

The difference is in how they are regulated. Your tap water is much more stringently regulated-- it is tested hundreds of times a month for over 100 different contaminants. Bottled water, on the other hand, is only required to be tested once a week for some substances. Higher levels of at least 13 contaminants are allowed in bottle water than tap water. And tap water providers are required to share their quality in reports such as this one, and to notify the public if a potentially dangerous contaminant is found. Bottled water providers are not required to provide the public with this information.

If you drink the recommended 8 cups of water a day of tap water it will cost you \$0.50 a year. The same amount of bottled water will cost \$1,400 a year. That's 3000x the price for a less safe product!

DRINKING WATER ANALYSIS
I&D SYSTEM

The City of Savannah Water Laboratory performed more than 135,000 tests and procedures, on over 160 water quality parameters, during 2014 to ensure water quality. The City has met all sampling and reporting requirements.

| Substance tested and detected | Chlorine | Chloramine | Total Trihalomethanes (TTHMs) | Total Haloacetic Acids (THAAs) | Total Organic Carbon | Turbidity | Lead | Copper |
|--|---------------------------------|---------------------------------|---------------------------------|---------------------------------|--------------------------------------|---|-------------------------------------|-------------------------------------|
| Probable Source | Added to water for disinfection | Added to water for disinfection | Byproduct of water chlorination | Byproduct of water chlorination | Naturally present in the environment | Soil runoff | Corrosion of household plumbing | Corrosion of household plumbing |
| Amount Detected | 2.38 ppm | 2.02 ppm | 75.6 ppb | 36.1 ppb | 53.4% removal | 0.19 NTU 100% samples | 2.5 ppb | 210 ppb |
| Meets Drinking Water Standards | | | | | | | | |
| Maximum Disinfectant Residual Level Goal The level of a drinking water disinfectant below which there is no known or expected risk to health | 4 ppm | 4 ppm | | | | | | |
| Maximum Disinfectant Residual Level Allowed The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants | 4 ppm | 4 ppm | | | | | | |
| Maximum Contaminant Level Goal The level of contaminant in drinking water below which there is no known or expected risk to health, allowing for a margin of safety. | | | 0 ppb | 0 ppb | Not Applicable | 0 NTU | 0 ppb | 1300 ppb |
| Maximum Contaminant Level Allowed The highest level of a contaminant that is allowed in drinking water. This level is set as close to the goal as feasible using the best available treatment technology. | | | 80 ppb | 60 ppb | Treatment technique | Treatment technique= 1NTU or 95% of samples < 0.3 NTU | | |
| Action Level The concentration of a contaminant which, if exceeded, triggers treatment or other requirements, which a water system must follow | | | | | | | 15 ppb | 1300 ppb |
| Range of Detection | 0.01-2.38 ppm | 0.01-2.02 ppm | 22.6-75.6 ppb | 19-51 ppb | 40.2-62.7% removal | Not applicable | No sample greater than action level | No sample greater than action level |

Units: ppm = parts per million or 1 in 1,000,000. ppb = parts per billion or 1 in 1,000,000,000. NTU= Nephelometric turbidity units
Treatment Technique: A required treatment technique or process intended to reduce the level of a contaminant in drinking water
 Copper and lead are the only two substances monitored at the customer's tap.

| Unregulated Contaminant Monitoring | | | | | | | | |
|------------------------------------|-----------------------|-------------|---------------------|-----------------------|--------------|--------------------------|-------------------------|-----------------------|
| | Molybdenum | Strontium | Hexavalent Chromium | Chromium | Vanadium | Perfluoro-heptanoic Acid | Perfluoro-octanoic Acid | 1,4- Dioxane |
| Amount Detected | 0.25 ppb | 43.9 ppb | 0.057 ppb | 0.18 ppb | 0.51 ppb | 0.0006 ppb | 0.001 ppb | 0.03 ppb |
| Range of Detection | not detected-0.42 ppb | 38-49.8 ppb | 0.013-0.11 ppb | not detected-0.24 ppb | 0.29-0.7 ppb | not detected-0.0035 ppb | not detected-0.0076 ppb | not detected-0.18 ppb |

The EPA selected the City of Savannah to participate in the Unregulated Contaminant Monitoring Regulation 3 (UCMR 3) program. Participants in UCMR3 are required to publish the results of the analysis of these unregulated contaminants. For more information on the contaminants or UCMR 3, please contact US EPA or GA Environmental Protection Division.

If you have any questions regarding safe drinking water regulations or these test results, you may contact the City of Savannah Water Supply and Treatment Department at (912) 964-0698

HEALTH INFORMATION: Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers.

EPA/Center for Disease control guidelines on appropriate means to lessen the risks of infection by Cryptosporidium and other microbial contaminants are available from the **Safe Drinking Water Hotline at 1-800-426-4791**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Savannah is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing fixtures. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have concerns about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the **Safe Drinking Water Hotline at 1-800-426-4791 OR AT www.epa.gov/safewater/lead**